



# **Data Concentrator TELEM-AGC**

## **User Manual**

**Martem AS**  
**2022**

# Contents

- 1. INTRODUCTION ..... 3
- 2. FEATURES ..... 3
- 3. TECHNICAL DATA ..... 5
- 4. TERMINAL CONNECTIONS ..... 7
- 5. COMMUNICATION CABLES ..... 8
- 6. DIGITAL INPUTS POWER SCHEME ..... 10
- 7. FIRMWARE UPDATE ..... 11
- 8. USING CONFIGURATION FROM SD CARD ..... 12
- 9. DIP SWITCHES ..... 12
- 10. INDICATION LED-S ..... 12
- 11. CONFIGURATION TOOL ..... 12
- 12. DATA OBJECTS SIMULATOR ..... 13
- 13. ORDER CODE ..... 14
- 14. MAINTENANCE GUIDELINES ..... 15
- 15. OPEN-SOURCE SOFTWARE INFORMATION ..... 15

## 1. Introduction



TELEM-AGC is designed for use in electrical networks as communication concentrator, firewall and 4G/3G/2G modem. The software bases on Linux operating system.

TELEM-AGC is the central unit of modular RTU (Remote Terminal Unit) system. It is expanded by DIN rail mounted Telem IO modules. It serves as communication device for data exchange between various substation devices and control centres.

The hardware modifications include digital IO signals, additional networking and serial interfaces.

The construction does not include moving parts as fans, rotating hard disk drives. For data storage the internal Flash memory and SD card is used.

## 2. Features

- Transparent TCP/IP connections via Ethernet and serial ports
- Various data exchange protocols via Ethernet and serial ports
- Cross-referencing of data exchange protocols
- Events (binary object's value changes) are buffered for case of possible communication failure. Every binary object has buffer with size of 20 events, so the total size of events buffer is no. of BI objects x 20
- Automatic protocol conversion from IEC 60870-5-101 to IEC 60870-5-104 without description of data objects.

- Firewall functionality
- OpenVPN, IPsec, L2TP and SSH connections
- SNMP (Simple Network Management Protocol)
- LDAP (Lightweight Directory Access Protocol)
- SDN (Software Defined Networking)
- DPI (Deep Packet Inspection)
- Logging of security events as remote connection and login attempts, RTU hardware and firmware errors to *messages* (syslog) and *console.log* files
- Graphic Web Server
- A user-friendly free configuration tool
- Configurable remotely over communication line
- Configuration export to ASCII, CSV format files
- Configuration can be stored in SD card, which can be used in replacement RTU
- TELEM RTU devices can be remotely configured via TELEM-AGC
- Logical operations between digital and analog signals
- Data sending with time and quality stamp
- Several time synchronization options (possible to synchronize from multiple control centers. TELEM-AGC is used to synchronize substation devices by protocol)
- GPS input
- NTP and PTP (IEEE1588v2) client and server
- Up to 5 Ethernet ports, 7 serial communication ports, all ports are galvanically isolated from case and power circuit
- Up to 16 digital inputs 6 double digital outputs (12 output relays)
- 1-wire sensor port (up to 10 sensors) e.g. for temperature sensor
- Real-time clock with back-up capacitor
- Support of predefined and dynamic data sets
- Support of Parallel Redundancy Protocol (PRP)
- Unlimited no. of datapoints, tested with 6000 datapoints
- Console port

### 3. Technical Data

#### Data communication protocols

To higher level systems:

- IEC 61850
- IEC 60870-5-104
- IEC 60870-5-101 unbalanced and balanced
- Modbus-RTU
- Modbus-TCP

To lower level devices:

- IEC 61850
- IEC 60870-5-104
- IEC 60870-5-103
- IEC 60870-5-101 Unbalanced
- Modbus-RTU
- Modbus-TCP
- SPA-Bus
- IEC 62056-21 (IEC 1107)

#### Communication ports

Depending on hardware configuration TELEM-AGC can have up to 5 Ethernet ports, and 7 serial communication ports.

Ports can be freely configured for upper or lower level communication.

#### Base board interfaces

- 2 x Ethernet connection with RJ45 port. 1,5kV isolation
- 1 x RS-232 with RJ12-6P6C connector, galvanically isolated. 15 kV surge protection
- 2 x RS-485/232 ports with RJ12-6P6C connectors for RS-232 and screw terminals for RS-485, galvanically isolated. 15 kV surge protection
- 1 x Console mini USB port
- 1 x multimode optical serial port or optical port for GPS interface connection
- 1-wire for environmental sensors

## Expansion modules

- Module C
  - 4 x RS-485/232 with optional redundant power input
- Module D
  - 8 optically isolated dry contact digital inputs (connected to dry contacts)
  - 3 double digital outputs (relay contacts max. 0.3A 110VDC, 2A 30VDC, 0.5A 125VAC)
- Module L    3 x RJ45 Eth.
- Module O    2 x Optical Eth. + RJ45 Eth.

## Serial data communication parameters

- 1 start bit
- Odd, even or no parity
- Communication rates from 300 to 115200 bit/sec

## Electromagnetic compatibility:

- Communication networks and systems for power utility automation                    IEC 61850-3
- Dielectric withstand    IEC 60255-5
- Withstand to static discharge    IEC 61000-4-2
- Withstand to surges, bursts    IEC 61000-4-4, 61000-4-5

## Mechanical parameters

- Degree of protection    IP 30
- Dimensions W x H x D (without connectors)    67 x 148 x 190 mm
- Ambient temperature in operation    -40°C...+70°C
- Weight    900 g
- Mounting    DIN rail
- Relative humidity    95% non-condensing


## Radio frequency compatibility

- RF emission    IEC 55022 Class A
- Immunity to RF fields    IEC 61000-4-3, 61000-4-6

## Power supply



- Supply voltage range    11...33 or 20...60 V DC
- Power consumption    < 7 W, < 18 W with optical Eth.

### 4. Terminal Connections




#### OPTIONAL INTERFACES



See order codes






### 5. Communication cables




The newer models of RTU-T have 6 pin RJ12 RS232 connectors, older - 4 pin RJ9







## 6. Digital inputs power scheme




DC power wires should not be grounded for maintaining the isolation of digital inputs.

## 7. Firmware update

**NB! Before updating to new firmware read the setup from your device, and make a backup.**

- Run **GWS.exe** and set up SSH connection with the device
- Press the **Upd▼** button next to **R W C** buttons
- If you have compressed .7z firmware update file (provided by Martem AS) choose **Update From File**



- If you do not have .7z firmware update file choose **Check martem.ee** to refresh existing firmware versions list for this AGC-L device
- Press **Update to feature** and choose needed firmware version. Download is starting...
- After firmware is downloaded **Confirm** window appears. Press **Yes** button, the update process starts
- Wait until the device resumes to its normal operation state (**RUN** LED will start slow blinking again), firmware update is complete.
- If a SD card is in it's slot when firmware updated over SSH the new firmware will be copied also to SD card

### Checking results of the firmware update operation:

- Press **R** button to read back the device setup data
- Check the **Version** from **GWS Status** tab

### Reading firmware back from device:

- Press the **Upd▼** button and choose **Read From Device**
- Follow dialog messages for uploading firmware.7z file

### Updating firmware from SD card:

- Put SD card with firmware into it's slot (firmware.7z file must be placed to SC card folder gwupd)
- Reboot AGC device to start firmware update

## 8. Using configuration from SD card

- Put SD card with config.tar.xz into its slot (config.tar.xz must be placed in SD folder "config")
- Reboot AGC device for loading configuration from SD card
- If a SD is in slot when configuration is loaded to AGC device over SSH (using GWS) the new setup.tar.xz will be written also to SD card folder "config". the previous setup.tar.xz will be renamed to setup.tar.xz.0 (previous setup.tar.xz.0 to setup.tar.xz.1 and so on)

## 9. DIP switches

**Reset:** Switch RESET to ON state and then back to OFF state for Reset operation

**Dft. Set:** To apply default setup:

1. Switch DFT. SET to ON state

\*Alert indication LED starts blinking within 5 seconds

\*Alert indication LED will blink for 2 seconds

2. Switch DFT. SET back to OFF state when the alert indication LED **is blinking** to apply default setup

\*If DFT. SET is switched back to OFF state when the alert indication LED is not blinking, default setup will NOT be applied

## 10. Indication LED-s

**MODEM** – green LED – indicates the 4G (3G) modem network connection

**RUN** – green LED – blinking green indicates that the program is running

**ALERT** – red LED – failure

Green LED-s on serial communication ports for RX, TX indication.

## 11. Configuration tool

The Telem-AGC device is configured with Telem-GWS software.

The configuration process is described in Telem-GWS software manual

## 12. Data objects simulator

The values of measurement objects of IEC 61850 and other protocols can be simulated on RTU's web page for testing the communication between RTU and SCADA

- Open web page with address [AGC device IP]/index2.html
- Select the device for object's simulation
- Press "Options" - "Enable Simulation" - "YES"
- Select measurement object from table - simulation window opens
- Set value for analog or binary signals and then press "Execute" (Value of binary signals could be changed also from buttons "ON" and "OFF")


The screenshot shows a web browser window titled "TELEM device monitor :: Martem" with the address bar displaying "172.16.0.177/index2.html#". The interface includes a navigation menu with "Channels", "Port1", "Device1", "GWMIO", "IEC-104 up", and "WebServer". The "Device1" tab is active, showing "Options" with "Enable Simulation" set to "Yes". A table lists measurement objects:

AI	5	AI 1	0.423
AI	6	AI 2	0.162
AI	7	AI 3	0.493
DI	11	DI 1	2
DI	12	DI 2	1
DI	13	DI 3	2

Two simulation windows are open: "AI 1" with a "Set value:" field containing "0.999" and buttons "Cancel", "Execute", and "Close"; and "DI 1" with a "Set value:" field containing "0", "OFF", and "ON" buttons, and buttons "Cancel", "Execute", and "Close".

## 13. Order code

### TELEM-AGC-XX-XX-XX-(XXX)



## 14. Maintenance guidelines

Device does not have any moving parts and does not need attention regarding mechanical wearing.

Maintenance consists of checking the *messages* (syslog) file for possible errors.

Messages file should not contain the words “Error” and “Fatal”.

Log files can be acquired using GWS configuration software.

For continuous monitoring of the health of the devices these can be tied to SNMP server software.

## 15. Open-source software information

**This device produced by Martem includes open-source components.** The most up to date info of exact software used by Martem’s build system and licensing info of used software can be found from <http://phobos.martem.ee/shr/br-sources/>